

Appendix G - Noise Monitoring Results

Location NC1 - True Light Middle School of Hong Kong							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	16:00	Sunny	69.7	72.7	62.9	70.2	69.7 Measured ≤ Baseline
11-Jan-11	16:40	Cloudy	65.4	67.8	62.3		65.4 Measured ≤ Baseline
18-Jan-11	17:30	Sunny	66.4	67.8	62.3		66.4 Measured ≤ Baseline
27-Jan-11	16:40	Sunny	67.7	69.4	64.3		67.7 Measured ≤ Baseline

Location NC2 - The Legend							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	14:20	Sunny	64.2	66.0	60.0	64.8	64.2 Measured ≤ Baseline
11-Jan-11	17:30	Cloudy	64.7	66.0	62.1		64.7 Measured ≤ Baseline
18-Jan-11	11:30	Sunny	59.8	61.7	56.2		59.8 Measured ≤ Baseline
27-Jan-11	17:25	Sunny	65.5	66.9	63.2		57.2

Location NC3 - Outside Aegean Terrace							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	9:15	Cloudy	55.3	57.7	50.9	57.7	55.3 Measured ≤ Baseline
11-Jan-11	8:20	Cloudy	55.9	58.2	50.4		55.9 Measured ≤ Baseline
18-Jan-11	8:20	Cloudy	55.3	57.1	50.9		55.3 Measured ≤ Baseline
27-Jan-11	8:20	Cloudy	54.7	56.9	50.0		54.7 Measured ≤ Baseline

Location NC4 - Man Yuen Garden							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	13:00	Sunny	72.8	75.7	64.5	64.5	72.1
11-Jan-11	13:00	Cloudy	72.9	75.7	66.7		72.2
18-Jan-11	13:00	Sunny	71.9	74.6	65.9		71.0
27-Jan-11	13:00	Sunny	70.1	72.8	64.7		68.7

Location NC5 - Bik D Villa Monte Rosa							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	10:45	Sunny	66.3	68.7	61.9	66.1	52.8
11-Jan-11	9:55	Cloudy	67.8	70.4	62.7		62.9
18-Jan-11	10:00	Sunny	67.2	69.0	62.0		60.7
27-Jan-11	9:55	Sunny	66.9	69.2	60.7		59.2

Location NC6 - Rosaryhill School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	10:05	Sunny	64.8	67.3	60.7	64.1	56.5
11-Jan-11	10:40	Cloudy	64.2	66.7	59.9		47.8
18-Jan-11	10:40	Sunny	64.8	66.9	60.4		56.5
27-Jan-11	10:35	Sunny	63.7	65.8	58.2		63.7 Measured ≤ Baseline

Location NC7 - Buddhist Li Ka Shing Care & Attention Home for the Elderly							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	15:10	Sunny	68.0	71.6	61.5	65.1	64.9
11-Jan-11	15:35	Cloudy	71.4	73.7	64.5		70.2
18-Jan-11	13:30	Sunny	74.5	77.8	66.7		74.0
27-Jan-11	15:40	Sunny	73.3	76.1	64.0		72.6

Appendix G - Noise Monitoring Results

Location NC8 - Marymount Secondary School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	10:50	Sunny	66.7	72.1	65.2	63.5	63.9
11-Jan-11	13:35	Cloudy	66.2	73.3	62.9		62.9
18-Jan-11	14:30	Sunny	66.8	73.8	63.1		64.1
27-Jan-11	13:00	Sunny	65.6	73.4	62.4		61.4

Location NC9 - 117 Blue Pool Road							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	10:15	Sunny	70.1	72.6	65.6	63.3	69.1
11-Jan-11	13:00	Cloudy	73.7	77.4	63.1		73.3
18-Jan-11	15:15	Sunny	72.8	73.3	63.1		72.3
27-Jan-11	13:35	Sunny	72.6	76.2	63.2		72.1

Location NC10 - The Harbour View							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	11:35	Sunny	71.0	73.8	66.8	71.7	71.0 Measured \leq Baseline
11-Jan-11	11:30	Cloudy	70.9	73.9	67.5		70.9 Measured \leq Baseline
18-Jan-11	11:30	Sunny	72.0	74.8	67.8		60.2
27-Jan-11	11:30	Sunny	72.3	75.1	68.0		63.4

Location NC11 - Honey Court							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	8:25	Cloudy	67.0	69.2	62.0	63.2	64.7
11-Jan-11	9:10	Cloudy	67.2	69.7	62.3		65.0
18-Jan-11	9:10	Sunny	63.9	66.3	59.7		55.6
27-Jan-11	9:05	Sunny	67.0	69.4	62.9		64.7

Location NC12 - Ying Wa Girl's School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	13:49	Sunny	64.2	66.9	60.3	67.1	64.2 Measured \leq Baseline
11-Jan-11	13:50	Cloudy	64.7	67.1	60.1		64.7 Measured \leq Baseline
18-Jan-11	14:00	Sunny	63.9	65.9	58.9		63.9 Measured \leq Baseline
27-Jan-11	13:50	Sunny	67.1	69.5	63.0		67.1 Measured \leq Baseline

Location NC13 - Peakville Court							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	14:30	Sunny	70.2	72.8	62.9	65.2	68.5
11-Jan-11	14:30	Cloudy	71.0	73.6	64.7		69.7
18-Jan-11	14:45	Sunny	70.8	72.9	64.1		69.4
27-Jan-11	14:30	Sunny	70.3	72.8	66.0		68.7

Appendix G - Noise Monitoring Results

Location NC14 - Hong Kong Japanese School							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	9:15	Sunny	65.7	70.3	61.8	60.8	64.0
11-Jan-11	14:30	Cloudy	65.1	71.0	61.2		63.1
18-Jan-11	16:00	Sunny	60.9	62.6	59.1		44.5
27-Jan-11	14:25	Sunny	64.7	66.2	56.3		62.4

Location NC15 - Hong Kong Academy							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	17:40	Cloudy	66.0	68.4	62.2	63.5	62.4
11-Jan-11	17:40	Cloudy	66.7	68.9	63.0		63.9
18-Jan-11	17:50	Cloudy	64.0	66.1	58.9		54.4
27-Jan-11	17:40	Cloudy	65.8	68.4	60.9		61.9

Location NC16 - Raimondi College							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	15:15	Sunny	63.7	65.9	60.1	70.4	63.7 Measured ≤ Baseline
11-Jan-11	15:15	Cloudy	64.0	66.3	58.7		64.0 Measured ≤ Baseline
18-Jan-11	15:30	Sunny	64.1	65.9	59.0		64.1 Measured ≤ Baseline
27-Jan-11	15:15	Sunny	65.9	68.4	60.9		65.9 Measured ≤ Baseline

Location NC17 - Hong Kong Institute of Technology							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	16:10	Cloudy	67.2	69.8	64.3	66.0	61.0
11-Jan-11	16:10	Cloudy	67.8	7.6	63.9		63.1
18-Jan-11	16:25	Sunny	68.2	71.0	63.7		64.2
27-Jan-11	16:10	Sunny	68.2	70.9	64.8		64.2

Location NC18 - Blk A, 80 Robinson Road							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	16:50	Cloudy	71.2	74.2	66.7	64.8	70.1
11-Jan-11	16:50	Cloudy	71.2	73.8	66.3		70.1
18-Jan-11	17:05	Cloudy	71.3	74.0	65.9		70.2
27-Jan-11	16:50	Cloudy	71.4	74.3	67.0		70.3

Location NC19 - Villa Veneto							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	17:20	Sunny	64.9	68.3	60.8	68.6	64.9 Measured ≤ Baseline
11-Jan-11	10:40	Cloudy	69.3	72.6	64.2		61.0
18-Jan-11	9:15	Sunny	69.5	72.8	66.7		62.2
27-Jan-11	10:55	Sunny	68.4	72.1	62.3		68.4 Measured ≤ Baseline

Location GNC7 - Hong Villa							
Date	Time	Weather	Unit: dB (A) (30-min)				
			Measured Noise Level			Baseline Level	Construction Noise Level
			L _{eq}	L ₁₀	L ₉₀	L _{eq}	L _{eq}
6-Jan-11	13:00	Sunny	56.6	57.8	53.4		
11-Jan-11	9:05	Cloudy	53.7	54.6	52.1		
18-Jan-11	10:45	Sunny	56.8	59.1	53.3		
27-Jan-11	9:00	Cloudy	54.2	54.9	52.0		

Appendix G - Noise Monitoring Results

(Restricted Hours - 07:00 to 23:00 holidays & 19:00 to 23:00 on all other days)

Location NC1a - Outside True Light Middle School of Hong Kong											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	(Reference) Baseline Level	(Reference) Construction Noise Level, L _{eq}			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
2-Jan-11	9:20	Cloudy	67.1	69.8	63.9	66.9	65.8	60.4			
	9:25		66.9	69.7	63.6						
	9:30		66.7	69.6	63.7						
6-Jan-11	19:00	Cloudy	67.8	70.6	64.2	67.5		65.8	62.6		
	19:05		67.5	70.3	64.5						
	19:10		67.3	70.0	64.3						
9-Jan-11	9:30	Sunny	67.2	70.2	64.5	66.9			65.8	60.4	
	9:35		66.8	69.9	64.3						
	9:40		66.6	69.9	63.8						
11-Jan-11	19:00	Cloudy	67.8	70.5	63.7	67.6				65.8	62.9
	19:05		67.6	70.2	63.2						
	19:10		67.3	69.8	63.5						
16-Jan-11	9:15	Sunny	68.0	69.8	66.7	67.7	65.8				63.2
	9:20		67.5	69.4	66.0						
	9:25		67.5	69.4	66.0						
18-Jan-11	19:00	Cloudy	67.0	69.7	63.7	67.1		65.8			61.2
	19:05		67.2	69.8	63.5						
	19:10		67.1	69.6	63.5						
23-Jan-11	9:00	Fine	66.5	68.6	64.0	66.5			65.8		58.2
	9:05		66.2	68.0	63.7						
	9:10		66.7	68.6	64.1						
27-Jan-11	19:05	Cloudy	67.1	69.8	64.0	66.8				65.8	59.9
	19:10		66.9	69.5	63.7						
	19:15		66.5	69.1	63.5						
30-Jan-11	9:05	Fine	66.0	68.1	64.3	66.2	65.8				55.6
	9:10		66.4	68.6	64.4						
	9:15		66.3	68.6	64.4						

(Restricted Hours - 07:00 to 23:00 holidays & 19:00 to 23:00 on all other days)

Location NC2 - The Legend											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	Baseline Level	Construction Noise Level			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
2-Jan-11	9:55	Cloudy	65.3	67.5	62.0	65.1	59.1	63.8			
	10:00		64.9	67.2	61.6						
	10:05		65.1	67.6	61.9						
6-Jan-11	19:35	Cloudy	65.7	68.4	60.9	65.5		59.1	64.4		
	19:40		65.4	68.2	61.0						
	19:45		65.5	68.2	61.2						
9-Jan-11	10:10	Sunny	65.5	67.5	61.7	65.3			59.1	64.1	
	10:15		64.9	67.3	61.4						
	10:20		65.4	67.5	61.4						
11-Jan-11	19:35	Cloudy	65.7	67.9	60.9	65.7				59.1	64.6
	19:40		65.4	67.8	60.8						
	19:45		66.0	68.5	61.2						
16-Jan-11	9:45	Sunny	63.4	66.7	60.8	63.4	59.1				61.4
	9:50		63.2	66.6	60.4						
	9:55		63.5	66.6	60.6						
18-Jan-11	19:35	Cloudy	65.1	67.0	60.7	64.9		59.1			63.6
	19:40		64.9	66.9	60.3						
	19:45		64.7	66.6	60.1						
23-Jan-11	9:40	Fine	62.8	65.0	60.3	62.7			59.1		60.2
	9:45		62.6	64.4	60.0						
	9:50		62.6	64.2	60.0						
27-Jan-11	19:40	Cloudy	65.1	67.3	60.9	64.9				59.1	63.6
	19:45		65.0	67.2	60.6						
	19:50		64.7	66.8	60.5						
30-Jan-11	9:45	Fine	62.4	65.0	60.3	63.2	59.1				61.1
	9:50		62.0	64.7	60.0						
	9:55		62.4	65.1	60.3						

(Restricted Hours - 07:00 to 23:00 holidays & 19:00 to 23:00 on all other days)

Location NC3 - Outside Aegean Terrace											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	Baseline Level	Construction Noise Level			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
2-Jan-11	11:00	Cloudy	52.6	54.3	47.9	52.2	53.8	52.2 Measured ≤ Baseline			
	11:05		52.2	54.7	47.5						
	11:10		51.9	54.1	47.5						
6-Jan-11	20:15	Cloudy	50.1	52.2	48.7	49.8		53.8	49.8 Measured ≤ Baseline		
	20:20		49.7	52.0	48.5						
	20:25		49.6	52.1	48.4						
9-Jan-11	11:10	Sunny	51.7	52.9	48.1	52.2			53.8	52.2 Measured ≤ Baseline	
	11:15		52.2	53.9	49.1						
	11:20		52.6	54.2	49.3						
11-Jan-11	20:20	Cloudy	50.3	52.5	48.3	50.3				53.8	50.3 Measured ≤ Baseline
	20:25		50.5	52.6	48.5						
	20:30		50.2	52.4	48.4						
16-Jan-11	10:50	Sunny	54.1	55.9	52.6	53.9	53.8				37.5
	10:55		54.0	55.9	52.5						
	11:00		53.6	55.7	52.0						
18-Jan-11	20:20	Cloudy	50.2	52.0	47.8	50.2		53.8			50.2 Measured ≤ Baseline
	20:25		50.0	52.0	47.5						
	20:30		50.3	52.1	47.7						
23-Jan-11	10:30	Fine	52.6	54.7	50.0	52.4			53.8		52.4 Measured ≤ Baseline
	10:35		52.4	54.2	50.0						
	10:40		52.2	54.1	49.9						
27-Jan-11	20:20	Cloudy	50.3	51.9	47.8	50.3				53.8	50.3 Measured ≤ Baseline
	20:25		50.1	51.8	47.9						
	20:30		50.4	52.4	47.7						
30-Jan-11	10:30	Fine	52.7	54.6	50.0	53.0	53.8				53.0 Measured ≤ Baseline
	10:35		53.0	54.7	50.4						
	10:40		53.2	54.9	50.7						

Appendix G - Noise Monitoring Results

(Restricted Hours - 23:00 to 07:00 on all days)

Location NC1a - Outside True Light Middle School of Hong Kong											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	(Reference) Baseline Level	(Reference) Construction Noise Level, L _{eq}			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
6-Jan-11	23:30	Fine	58.7	60.2	55.5	59.5	60.7	59.5 Measured ≤ Baseline			
	23:35		59.6	61.4	55.7						
	23:40		60.2	61.9	54.9						
11-Jan-11	23:35	Fine	60.2	62.3	56.4	60.1		60.7	60.1 Measured ≤ Baseline		
	23:40		59.7	62.1	56.1						
	23:45		60.5	62.1	56.8						
18-Jan-11	23:00	Cloudy	60.2	63.1	58.4	59.8			60.7	59.8 Measured ≤ Baseline	
	23:05		59.7	62.9	58.0						
	23:10		59.4	62.5	57.7						
27-Jan-11	23:00	Fine	59.6	61.3	56.7	59.6				60.7	59.6 Measured ≤ Baseline
	23:05		59.6	61.3	56.6						
	23:10		59.7	61.5	56.9						




(Restricted Hours - 23:00 to 07:00 on all days)

Location NC2 - The Legend											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	Baseline Level	Construction Noise Level			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
6-Jan-11	23:00	Fine	53.7	55.8	49.3	53.5	53.9	53.5 Measured ≤ Baseline			
	23:05		53.5	55.5	49.1						
	23:10		53.2	54.9	48.9						
11-Jan-11	23:00	Fine	53.3	55.1	49.9	53.1		53.9	53.1 Measured ≤ Baseline		
	23:05		52.9	54.9	50.1						
	23:10		53.0	55.2	50.2						
18-Jan-11	23:35	Cloudy	52.6	54.0	50.2	52.5			53.9	52.5 Measured ≤ Baseline	
	23:40		52.6	54.1	50.2						
	23:45		52.4	53.9	50.0						
27-Jan-11	23:40	Fine	52.6	54.6	50.1	52.8				53.9	52.8 Measured ≤ Baseline
	23:45		52.9	54.7	50.3						
	23:50		53.0	54.9	50.5						

(Restricted Hours - 23:00 to 07:00 on all days)




Location NC3 - Outside Aegean Terrace											
Date	Time	Weather	dB (A) (5-min)			Average L _{eq}	Baseline Level	Construction Noise Level			
			L _{eq}	L ₁₀	L ₉₀		L _{eq}	L _{eq}			
7-Jan-11	0:20	Fine	51.6	52.9	48.7	52.4	52.0	41.8			
	0:25		52.6	53.9	49.5						
	0:30		52.8	54.3	49.8						
12-Jan-11	0:25	Fine	51.3	52.5	47.9	50.9		52.0	50.9 Measured ≤ Baseline		
	0:30		50.4	51.9	47.6						
	0:35		50.9	52.1	48.1						
19-Jan-11	0:20	Cloudy	49.8	51.7	46.3	49.9			52.0	49.9 Measured ≤ Baseline	
	0:25		50.2	52.1	46.4						
	0:30		49.8	51.8	46.3						
28-Jan-11	0:30	Fine	46.7	49.3	44.2	46.9				52.0	46.9 Measured ≤ Baseline
	0:35		46.8	49.3	44.4						
	0:40		47.3	50.0	45.1						

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA8001	CINOTECH
	Date Jan 11	Appendix G	

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels





Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels






Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	

Noise Levels (Restricted Hours - 07:00 - 23:00 holidays & 19:00 - 23:00 on all other days)



Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale N.T.S	Project No. MA8001	
	Date Jan 11	Appendix G	

Noise Levels (Restricted Hours - 23:00 to 07:00 on all days)



Title Contract No. DC/2007/10 Design and Construction of Hong Kong West Drainage Tunnel Graphical Presentation of Construction Noise Monitoring Results	Scale	N.T.S	Project No.	MA8001	CINOTECH
	Date	Jan 11	Appendix	G	