

1-hour TSP Monitoring Results

Station CM_AB1a, The Hong Kong Ice and Cold Storage (Aberdeen)

Date	Start Time	Finish Time	Weather	TSP Concentration ($\mu\text{g}/\text{m}^3$)	Action Level ($\mu\text{g}/\text{m}^3$)	Limit Level ($\mu\text{g}/\text{m}^3$)	Site Conditions / Observations / Remarks	Temperature ($^{\circ}\text{C}$)	Wind Speed (m/s)	Sampler ID	Filter ID
04/10/2010	13:15	14:15	Fine	67	283	500	Grouting works and pipe piling	25.5	<5	LD-3B-001	N/A
04/10/2010	14:15	15:15	Fine	70	283	500	Grouting works and pipe piling	25.5	<5	LD-3B-001	N/A
04/10/2010	15:15	16:15	Fine	65	283	500	Grouting works and pipe piling	25.5	<5	LD-3B-001	N/A
08/10/2010	09:16	10:16	Fine	105	283	500	Grouting works and pipe piling	25.8	<5	LD-3B-001	N/A
08/10/2010	10:16	11:16	Fine	88	283	500	Grouting works and pipe piling	25.8	<5	LD-3B-001	N/A
08/10/2010	11:16	12:16	Fine	75	283	500	Grouting works and pipe piling	25.8	<5	LD-3B-001	N/A
14/10/2010	13:07	14:07	Cloudy	87	283	500	Pipe piling	27.9	<5	LD-3B-001	N/A
14/10/2010	14:07	15:07	Cloudy	93	283	500	Pipe piling	27.9	<5	LD-3B-001	N/A
14/10/2010	15:07	16:07	Cloudy	90	283	500	Pipe piling	27.9	<5	LD-3B-001	N/A
20/10/2010	13:00	14:00	Sunny	67	283	500	Pipe piling	26.4	<5	LD-3B-001	N/A
20/10/2010	14:00	15:00	Sunny	67	283	500	Pipe piling	26.4	<5	LD-3B-001	N/A
20/10/2010	15:00	16:00	Sunny	72	283	500	Pipe piling	26.4	<5	LD-3B-001	N/A
26/10/2010	13:05	14:05	Sunny	21	283	500	Pipe piling	22.3	<5	LD-3B-001	N/A
26/10/2010	14:05	15:05	Sunny	25	283	500	Pipe piling	22.3	<5	LD-3B-001	N/A
26/10/2010	15:05	16:05	Sunny	23	283	500	Pipe piling	22.3	<5	LD-3B-001	N/A
				Min.	21						
				Max.	105						
				Average	68						