

1-hour TSP Monitoring Results

Station CM_CB1a, The Arcade, Cyberport

Date	Start Time	Finish Time	Weather	TSP Concentration (µg/m ³)	Action Level (µg/m ³)	Limit Level (µg/m ³)	Site Conditions / Observations / Remarks	Temperature (°C)	Wind Speed (m/s)	Sampler ID	Filter ID
04-Oct-13	09:00	10:00	Sunny	263	279.9	500	Instllaing the extention noise enclosure	26.7	<5	LD-3B-002	N/A
04-Oct-13	10:00	11:00	Sunny	248	279.9	500	Instllaing the extention noise enclosure	26.7	<5	LD-3B-002	N/A
04-Oct-13	11:00	12:00	Sunny	231	279.9	500	Instllaing the extention noise enclosure	26.7	<5	LD-3B-002	N/A
10-Oct-13	13:03	14:03	Fine	72	279.9	500	Instllaing the extention noise enclosure	27	<5	LD-3B-002	N/A
10-Oct-13	14:03	15:03	Fine	75	279.9	500	Instllaing the extention noise enclosure	27	<5	LD-3B-002	N/A
10-Oct-13	15:03	16:03	Fine	67	279.9	500	Instllaing the extention noise enclosure	27	<5	LD-3B-002	N/A
16-Oct-13	09:00	10:00	Fine	263	279.9	500	Operation of concrete pump	25.8	<5	LD-3B-002	N/A
16-Oct-13	10:00	11:00	Fine	242	279.9	500	Operation of concrete pump	25.8	<5	LD-3B-002	N/A
16-Oct-13	11:00	12:00	Fine	187	279.9	500	Operation of concrete pump	25.8	<5	LD-3B-002	N/A
22-Oct-13	08:56	09:56	Fine	229	279.9	500	Operation of concrete pump	25.1	<5	LD-3B-002	N/A
22-Oct-13	09:56	10:56	Fine	238	279.9	500	Operation of concrete pump	25.1	<5	LD-3B-002	N/A
22-Oct-13	10:56	11:56	Fine	229	279.9	500	Operation of concrete pump	25.1	<5	LD-3B-002	N/A
28-Oct-13	13:04	14:04	Fine	117	279.9	500	Operation of concrete pump	22.8	<5	LD-3B-002	N/A
28-Oct-13	14:04	15:04	Fine	108	279.9	500	Operation of concrete pump	22.8	<5	LD-3B-002	N/A
28-Oct-13	15:04	16:04	Fine	108	279.9	500	Operation of concrete pump	22.8	<5	LD-3B-002	N/A
			Min.	67							
			Max.	263							
			Average	178							