

1-hour TSP Monitoring Results

Station CM_WF1a, The Wah Ming House

Date	Start Time	Finish Time	Weather	TSP Concentration ($\mu\text{g}/\text{m}^3$)	Action Level ($\mu\text{g}/\text{m}^3$)	Limit Level ($\mu\text{g}/\text{m}^3$)	Site Conditions / Observations / Remarks	Temperature ($^{\circ}\text{C}$)	Wind Speed (m/s)	Sampler ID	Filter ID
03-Mar-14	09:17	10:17	Sunny	273	284.5	500	Loading concrete	15.8	<5	LD-3B-001	N/A
03-Mar-14	10:17	11:17	Sunny	280	284.5	500	Loading concrete	15.8	<5	LD-3B-001	N/A
03-Mar-14	11:17	12:17	Sunny	273	284.5	500	Loading concrete	15.8	<5	LD-3B-001	N/A
07-Mar-14	09:14	10:14	Sunny	164	284.5	500	Loading concrete	14.6	<5	LD-3B-001	N/A
07-Mar-14	10:14	11:14	Sunny	147	284.5	500	Loading concrete	14.6	<5	LD-3B-001	N/A
07-Mar-14	11:14	12:14	Sunny	173	284.5	500	Loading concrete	14.6	<5	LD-3B-001	N/A
12-Mar-14	09:23	10:23	Sunny	246	284.5	500	Loading concrete	17.7	<5	LD-3B-001	N/A
12-Mar-14	10:23	11:23	Sunny	280	284.5	500	Loading concrete	17.7	<5	LD-3B-001	N/A
12-Mar-14	11:23	12:23	Sunny	280	284.5	500	Loading concrete	17.7	<5	LD-3B-001	N/A
17-Mar-14	09:20	10:20	Foggy	269	284.5	500	Loading concrete	20.4	<5	LD-3B-001	N/A
17-Mar-14	10:20	11:20	Foggy	276	284.5	500	Loading concrete	20.4	<5	LD-3B-001	N/A
17-Mar-14	11:20	12:20	Foggy	278	284.5	500	Loading concrete	20.4	<5	LD-3B-001	N/A
21-Mar-14	09:20	10:20	Foggy	265	284.5	500	Loading concrete	16.5	<5	LD-3B-001	N/A
21-Mar-14	10:20	11:20	Foggy	250	284.5	500	Loading concrete	16.5	<5	LD-3B-001	N/A
21-Mar-14	11:20	12:20	Foggy	273	284.5	500	Loading concrete	16.5	<5	LD-3B-001	N/A
27-Mar-14	09:35	10:35	Sunny	91	284.5	500	Loading concrete	23.5	<5	LD-3B-001	N/A
27-Mar-14	10:35	11:35	Sunny	91	284.5	500	Loading concrete	23.5	<5	LD-3B-001	N/A
27-Mar-14	11:35	12:35	Sunny	61	284.5	500	Loading concrete	23.5	<5	LD-3B-001	N/A
				Average							
				Maximum							
				Minimum							