

## Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

| Location M8 (Aberdeen PTW)<br>The rooftop of Wah Lai House |       |         |                       |                 |                 |                 |                          |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|--------------------------|
| Date   | Time  | Weather | Unit: dB (A) (30-min) |                 |                 |                 |                          |
|  |       |         | Measured Noise Level  |                 |                 | Baseline Level  | Construction Noise Level |
|  |       |         | L <sub>eq</sub>       | L <sub>10</sub> | L <sub>90</sub> | L <sub>eq</sub> | L <sub>eq</sub>          |
| 3-Oct-18   | 09:45 | Sunny   | 66                    | 67              | 62              | 64              | 63                       |
| 9-Oct-18   | 10:00 | Sunny   | 68                    | 68              | 63              |                 | 66                       |
| 15-Oct-18  | 11:00 | Cloudy  | 66                    | 67              | 60              |                 | 62                       |
| 25-Oct-18  | 09:30 | Sunny   | 64                    | 67              | 59              |                 | 64 Measured ≤ Baseline   |
| 31-Oct-18  | 09:10 | Sunny   | 70                    | 72              | 69              |                 | 69                       |
| <b>Minimum</b>   |       |         | <b>64</b>             |                 |                 |                 |                          |
| <b>Maximum</b>   |       |         | <b>70</b>             |                 |                 |                 |                          |
| <b>Average</b>   |       |         | <b>67</b>             |                 |                 |                 |                          |