

Restricted Hours Noise Monitoring Results -- Night time

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
12-Jan-11	23:00	23:15	Fine	53	55	51	No major constructin works	Cars from residents of Aegean Terence, helicopter fly over head	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	8.8	<5	ONO SOKKI LA-5110 S/N: 72700154	ONO SOKKI SC-2110 S/N: 00461
25-Jan-11	23:00	23:15	Fine	53	56	49	No major constructin works	Cars from residents of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	14.3	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2656516
				Min.	53								
				Max.	53								