Restricted Hours Noise Monitoring Results -- Night time

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (℃)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
09-Jun-11	23:00	23:15	Fine	57	58	52	No major constructin works	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	30.0	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2656516
			Min.	57									
			Max.	57									