

Restricted Hours Noise Monitoring Results -- Night time

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction	Other Noise Source(s)	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
06-Sep-11	23:00	23:15	Fine	57	58	53	Operation of excavator for loading	Local traffics of Aegean Terrace	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	29	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 2385180
20-Sep-11	23:00	23:15	Fine	52	54	50	No major constructin works	Local traffics of Aegean Terrace	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	26	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2656516
				Min.	52								
				Max.	57								