

Daytime Noise Monitoring Results -- Normal weekday

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction	Other Noise Source(s)	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq *	L10	L90							
03-Dec-12	10:59	11:29	Fine	54.4	56.9	48.8	Rock out	N.A	Free-field measurement, +3dB correction.	17.1	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
13-Dec-12	10:19	10:49	Fine	59.7	62.4	50.0	operatorion of excavator	N.A	Free-field measurement, +3dB correction.	18.9	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
19-Dec-12	10:38	11:08	Fine	56.5	58.5	49.8	operatorion of excavator	N.A	Free-field measurement, +3dB correction.	15.1	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
27-Dec-12	14:28	14:58	Fine	59.3	61.6	54.2	Rock out	N.A	Free-field measurement, +3dB correction.	18.6	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
				Min.	54.4								
				Max.	59.7								

Remark: Free-field measurement, +3dB correction.