

Restricted Hours Noise Monitoring Results -- Evening time

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s)	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Jan-12	22:45	23:00	Fine	49	50	48	No major constructin works	Local traffics of Aegean Terence and helicopter fly over head	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	14.0	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
19-Jan-12	22:45	23:00	Fine	59	60	56	No major constructin works	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	14.0	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2656516
				Min.	49								
				Max.	59								