## Restricted Hours Noise Monitoring Results -- Evening time Station M6a, Aegean Terrace

DateStart TimeEnd TimeWeather LeqLeqL10L90Construction Noise Source(s)Other Noise Source(s)RemarksTemp. (°C)Speed (m/s)Noise Meter Model / IDCalibrator Model / ID15-Aug-1322:4523:00Fine555651Vorks inside tunnelLocal traffics of Aegean TerenceAccording to construction works was in accordance to CNP.28.24-5B&K 2238 S/N: 2800932B&K 4231 S/N: 3003246	Date			Weather	Noise level (dB(A)), 5 min			Major	Other Noise			Wind	
15-Aug-13 22:45 23:00 Fine 55 56 51 Works inside Local traffics of Aegean Terence CONP. +3dB SECTION AND ADDRESS SECTION AND ADDRESS SECTION					Leq	L10	L90	Noise Source(s)	Source(s)	Remarks		Speed	
	15-Aug-13	22:45	23:00	Fine	55	56	51			contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB	28.2	<5	

 Min.
 55.0

 Max.
 55.0