

**Daytime Noise Monitoring Results -- Normal weekday**  
**Station M6a, Aegean Terrace**

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq *	L10	L90							
02-Jul-13	15:20	15:50	Sunny	54.6	55.1	50.8	Tunnel works and operation of concrete pump	N.A	Free-field measurement, +3dB correction.	29.4	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
09-Jul-13	14:02	14:32	Sunny	56.6	57.7	53.4	Tunnel works and operation of concrete pump	N.A	Free-field measurement, +3dB correction.	29.0	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
15-Jul-13	10:44	11:14	Cloudy	58.2	59.2	53.8	Tunnel works and operation of concrete pump	N.A	Free-field measurement, +3dB correction.	26.0	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
24-Jul-13	15:16	15:46	Cloudy	57.1	58.2	53.2	Tunnel works and operation of concrete pump	N.A	Free-field measurement, +3dB correction.	26.0	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
31-Jul-13	10:40	11:10	Sunny	58.5	59.7	54.7	Tunnel works and operation of concrete pump	N.A	Free-field measurement, +3dB correction.	29.4	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3004068
				Min.	54.6								
				Max.	58.5								

Remark: Free-field measurement, +3dB correction.