

Restricted Hours Noise Monitoring Results -- Evening Time and Daytime on Public Holiday

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction	Other Noise Source(s)	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Mar-13	14:05	14:20	Fine	58	60	52	No major construction works	Local traffics of Aegean Terrace	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	15.3	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
				Min.	58								
				Max.	58								

Restricted Hours Noise Monitoring Results -- Evening time

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction	Other Noise Source(s)	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
12-Mar-13	22:45	23:00	Fine	53	55	49	Works inside tunnel	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	20.4	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
				Min.	53								
				Max.	53								