Restricted Hours Noise Monitoring Results -- Evening time

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min									
				Leq	L10	L90	Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
24-Oct-13	22:45	23:00	Fine	51	54	45	Works inside tunnel	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	24.4	<5	B&K 2238 S/N : 2800932	B&K 4231 S/N: 3003246
	Min.	51											
	Max.	51											