

Evening time Noise Monitoring Results

Station M6a, Aegean Terrace

Date	Start Time	End Time	Weather	Noise level (dB(A))			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
09/10/14-a	22:45	22:50	Fine	47	48	39	Nil	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	26.5	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004038
09/10/14-b	22:50	22:55	Fine	46	49	39				26.5	<5		
09/10/14-c	22:55	23:00	Fine	47	49	42				26.5	<5		
09-Oct-14	22:45	23:00	Fine	49	51	43	Nil	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	26.5	<5	B&K 2238 S/N :2684503	B&K 4231 S/N: 3004068
24/10/14-a	22:45	22:50	Fine	49	51	46	Nil	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	24.8	<5	B&K 2238 S/N : 2800932	B&K 4231 S/N: 3003246
24/10/14-b	22:50	22:55	Fine	49	52	44				24.8	<5		
24/10/14-c	22:55	23:00	Fine	46	49	42				24.8	<5		
24-Oct-14	22:45	23:00	Fine	51	54	47	Nil	Local traffics of Aegean Terence	According to contractor, general construction works was in process accordance to CNP. Free-field measurement, +3dB correction.	24.8	<5	B&K 2238 S/N :2800932	B&K 4231 S/N: 3003246
				Max	51								
				Min	46								
				Average	48								