

Restricted Hours Noise Monitoring Results -- Evening time

Station M3, Kwan Yick building

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s)	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Aug-10	22:45	23:00	Fine	66	67	63	Operating bentonite filtering plant and hydraulic excavator	Traffic noise	N.A	29	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
09-Aug-10	22:45	23:00	Fine	65	67	64	Operating bentonite filtering plant and hydraulic excavator	Traffic noise	N.A	30	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
17-Aug-10	22:45	23:00	Cloudy	66	68	64	Operating bentonite filtering plant and hydraulic excavator	Traffic noise	N.A	28	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
				Min.	65								
				Max.	66								