

**Daytime Noise Monitoring Results -- Normal weekday**

**Station M3, Kwan Yick building(\*)**

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
06-May-11	14:35	15:05	Fine	69	70	67	Lifting, excavation work	Mainly traffic noise	-	27.0	0.3	RION- NL31 (S/N 00983400)	RION - NC73 (S/N 10997142)
12-May-11	10:25	10:55	Sunny	70	71	67	Lifting, excavation work	Mainly traffic noise	-	30.0	0.5	RION- NL31 (S/N 00983400)	RION - NC73 (S/N 10997142)
18-May-11	10:45	11:15	Sunny	69	70	66	Lifting, excavation work	Mainly traffic noise	-	25.0	0.4	RION- NL31 (S/N 00983400)	RION - NC73 (S/N 10997142)
24-May-11	13:20	13:50	Cloudy	69	70	66	Lifting, excavation work	Mainly traffic noise	-	22.0	0.5	RION- NL31 (S/N 00983400)	RION - NC73 (S/N 10997142)
30-May-11	10:43	11:13	Sunny	69	70	67	Lifting, excavation work	Mainly traffic noise	-	26.0	0.2	RION- NL31 (S/N 00983400)	RION - NC73 (S/N 10997142)
				<b>Min.</b>	<b>69</b>								
				<b>Max.</b>	<b>70</b>								

Remark: (\*): The data were provided by Contract No. DC/2007/23. Calibration certificates for the noise meter(s) and calibrator(s) used were included in the corresponding Monthly EM&A Report for this Contract