

Restricted Hours Noise Monitoring Results -- Daytime on Public Holiday

Station M3, Kwan Yick building

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s)	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
08-Jul-12	11:26	11:41	Fine	65	66	63	No outdoor construction noise	Mainly traffic noise	-	30	0.3	RION- NL31 (S/N 00603867)	RION - NC73 (S/N 10997142)
15-Jul-12	13:54	14:09	Sunny	66	69	63	No outdoor construction noise	Mainly traffic noise	-	30	<5	B&K 2238 S/N: 2385180	B&K 4231 S/N: 2656516
22-Jul-12	09:34	09:49	Sunny	65	66	63	No outdoor construction noise	Mainly traffic noise	-	27	0.2	RION- NL31 (S/N 00710259)	RION - NC73 (S/N 10997142)
				Min.	65								
				Max.	66								

Remark: The data (8 and 22 July) was provided by Contract No. DC/2007/23. Calibration certificates for the noise meter(s) and calibrator(s) used were included in the corresponding Monthly EM&A Report for this Contract

Restricted Hours Noise Monitoring Results -- Evening time

Station M3, Kwan Yick building

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s)	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Jul-12	19:35	19:50	Fine	68	69	65	No outdoor construction noise	Mainly traffic noise	-	30	0.2	RION- NL31 (S/N 00603867)	RION - NC73 (S/N 10997142)
17-Jul-12	19:35	19:50	Fine	66	67	64	No outdoor construction noise	Mainly traffic noise	-	30	0.3	RION- NL31 (S/N 00710259)	RION - NC73 (S/N 10997142)
19-Jul-12	22:45	23:00	Fine	66	68	64	No outdoor construction noise	Mainly traffic noise	-	30.2	0.5	B&K 2238 S/N: 2385180	B&K 4231 S/N: 2656516
31-Jul-12	22:19	22:34	Fine	63	64	61	No outdoor construction noise	Mainly traffic noise	-	27	0.2	RION- NL31 (S/N 00710259)	RION - NC73 (S/N 10997142)
				Min.	63								
				Max.	68								

[1] The data (M3_Evening Time) of 3, 17 and 31 July were provided by Contract No. DC/2007/23. Calibration certificates for the noise meter(s) and calibrator(s) used were included in the corresponding Monthly EM&A Report for this Contract