

Restricted Hours Noise Monitoring Results -- Evening time

Station M3, Kwan Yick building

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
05-Jun-12	20:01	20:16	Fine	66	67	64	No outdoor construction noise	Mainly traffic noise	-	28.0	0.5	RION- NL31 (S/N 00603867)	RION - NC73 (S/N 10997142)
19-Jun-12	19:32	19:47	Fine	66	68	65	No outdoor construction noise	Mainly traffic noise	-	28.0	0.5	RION- NL31 (S/N 00603867)	RION - NC73 (S/N 10997142)
27-Jun-12	22:45	23:00	Fine	66	68	64	No outdoor construction noise	Mainly traffic noise	-	29.4	0.5	B&K 2238 S/N: 2385180	B&K 4231 S/N: 2656516
				Min.	66								
				Max.	66								

[1] The data (M3_Evening Time) of 5 and 19 June were provided by Contract No. DC/2007/23. Calibration certificates for the noise meter(s) and calibrator(s) used were included in the corresponding Monthly EM&A Report for this Contract