

Daytime Noise Monitoring Results

Station NM6 Customs' Marine Base (Block H of Government Dockyard) Rooftop

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min ⁺			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Mean Temp. (°C)	Mean Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Aug-10	14:15	14:45	Sunny	70	71	69	excavation in process and crane in operation	other construction site nearby	-	29.1	<5 m/s	B&K 2238	B&K 4231
09-Aug-10	14:30	15:00	Sunny	67	68	67	excavation in process and crane in operation	other construction site nearby	-	29.6	<5 m/s	B&K 2238	B&K 4231
21-Aug-10	11:00	11:30	Sunny	72	73	70	excavation in process and crane in operation	other construction site nearby	-	29.4	<5 m/s	B&K 2238	B&K 4231
27-Aug-10	10:30	11:00	Sunny	70	71	68	excavation in process and crane in operation	other construction site nearby	-	28.8	<5 m/s	B&K 2238	B&K 4231
			Min.	67									
			Max.	72									

⁺ - Façade measurement