

Restricted Hours Noise Monitoring Results (Evening Time)

Station NM6 Customs' Marine Base (Block H of Government Dockyard) Rooftop

Date	Start Time	End Time	Weather	Noise level (dB(A)), 5 min ⁺			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Mean Temp. (°C)	Mean Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
06-Dec-10	19:54	19:59	Fine	65	66	64	excavation in process	traffic noise from nearby pier	-	23.5	<5 m/s	B&K 2238	B&K 4231
	19:59	20:04		65	66	64							
	20:04	20:09		65	66	64							
16-Dec-10	22:02	22:07	Fine	63	64	63	excavation in process	traffic noise from nearby pier	-	14.3	<5 m/s	B&K 2250L	B&K 4231
	22:07	22:12		64	65	63							
	22:12	22:17		64	64	63							
23-Dec-10	19:05	19:10	Fine	68	69	67	excavation in process	traffic noise from nearby pier	-	18.1	<5 m/s	B&K 2250L	B&K 4231
	19:10	19:15		68	70	66							
	19:15	19:20		68	70	66							
30-Dec-10	19:05	19:10	Fine	63	64	63	excavation in process and crane in operation	traffic noise from nearby pier	-	17.8	<5 m/s	B&K 2270	B&K 4231
	19:10	19:15		64	65	63							
	19:15	19:20		63	64	62							
				Min.	63								
				Max.	68								

* - Façade measurement