Daytime Noise Monitoring Results

Station M7, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (℃)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
02-Jul-10	10:07	10:37	Sunny	59	60	57	N.A	N.A	N.A	30	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
08-Jul-10	09:04	09:34	Sunny	65	68	61	Grouting works	Repaving floor construction at Wah Ching House	N.A	30.6	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
13-Jul-10	11:03	11:33	Sunny	61	62	59	Operation of hydrulic excavator	Repaving floor construction at Wah Ching House	N.A	29.9	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
20-Jul-10	09:19	09:49	Sunny	63	64	61	Operation of hydrulic excavator	N.A	N.A	29.5	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
26-Jul-10	09:32	10:02	Sunny	63	64	60	Operation of hydrulic excavator	N.A	N.A	29.2	<5	B&K 2238 S/N : 2684502	B&K 4231 S/N: 2385180
			Min.	**59**									
			Max.	**68**									