

## Daytime Noise Monitoring Results

### Station M7, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-May-10	13:00	13:30	Sunny	61	62	60	Operation of Mobile crane and pipe piling work	Celling water-proof construction at Wah Mei House and removal asbestos at Wah Hong House	N.A	24.2	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 2385180
12-May-10	13:09	13:39	Sunny	61	63	59	Pipe piling work	Celling water-proof construction at Wah Mei House and removal asbestos at Wah Hong House	N.A	24	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 2385180
18-May-10	09:15	09:45	Sunny	65	67	62	Pipe piling work	Repaving floor construction at Wah Ching House	N.A	27.3	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 2385180
28-May-10	09:40	10:10	Sunny	63	65	61	Pipe piling work	Repaving floor construction at Wah Cheung House	N.A	26.9	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 2385180
				<b>Min.</b>	<b>61</b>								
				<b>Max.</b>	<b>65</b>								