Daytime Noise Monitoring Results
Station M7a, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
05-May-14	09:17	09:47	Fine	68	69	68	N.A	operaction of excavator in near construction site	N.A	21.8	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3003246
12-May-14	09:40	10:10	Cloudy	68	68	67	N.A	operaction of excavator in near construction site	N.A	25.8	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3003246
19-May-14	13:49	14:19	Sunny	71	74	67	N.A	operaction of mobile crane in near construction site	N.A	28.9	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068
28-May-14	10:08	10:38	Sunny	70	72	69	N.A	operaction of mobile crane in near construction site	N.A	29.4	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068

Maximum	71
Minimum	68
Average	69