

Noise Monitoring Results

(0700-1900 hrs on Normal Weekdays)

| Location M7a (Wah Fu PTW) The rooftop of Wah Ming House | | | | | | | |
|--|-------|---------|-----------------------|-----------------|-----------------|-----------------|-----------------------------|
| Date | Time | Weather | Unit: dB (A) (30-min) | | | | |
| | | | Measured Noise Level | | | Baseline Level | Construction Noise Level |
| | | | L _{eq} | L ₁₀ | L ₉₀ | L _{eq} | L _{eq} |
| 3-Nov-14 | 08:36 | Cloudy | 57 | 61 | 51 | 59 | 57 Measured \leq Baseline |
| 13-Nov-14 | 13:10 | Cloudy | 57 | 59 | 54 | | 57 Measured \leq Baseline |
| 19-Nov-14 | 08:58 | Sunny | 52 | 53 | 49 | | 52 Measured \leq Baseline |
| 25-Nov-14 | 13:05 | Sunny | 62 | 65 | 59 | | 60 |
| Max. | | | 62 | | | | |
| Min. | | | 52 | | | | |
| Average | | | 57 | | | | |