

Daytime Noise Monitoring Results -- Normal weekday

Station M7a, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction	Other Noise Source(s)	Remarks	Temp. (°C)	Wind Speed	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
03-Apr-13	09:22	09:52	Sunny	70.4	72.8	66.5	Operatorion of mobile crane and loading	Drilling at near construction site	N.A	19	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
09-Apr-13	09:26	09:56	Sunny	65.7	67.3	60.4	Operatorion of mobile crane and loading	N.A	N.A	19	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
15-Apr-13	09:17	09:47	Sunny	61.0	62.7	58.2	Operatorion of mobile crane and loading	N.A	N.A	23	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
24-Apr-13	09:19	09:49	Sunny	63.9	65.4	60.7	Operatorion of mobile crane and loading	N.A	N.A	25	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
29-Apr-13	09:10	09:40	Sunny	63.9	65.8	62.4	Operatorion of mobile crane and loading	N.A	N.A	24	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3003246
				Min.	61.0								
				Max.	70.4								