Daytime Noise Monitoring Results -- Normal weekday

Station M7a, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
06-Aug-13	13:01	13:31	Sunny	70.8	73.7	62.1	Mucking out	Mini piling in process in adjacent site	N.A	30	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3004068
12-Aug-13	17:09	17:39	Sunny	75.0	77.0	71.3	Operation of mobile crane	Mini piling in process in adjacent site	N.A	31	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3004068
22-Aug-13	10:11	10:41	Fine	74.6	79.5	63.4	Operation of mobile crane	Mini piling in process in adjacent site	N.A	29	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3004068
28-Aug-13	09:41	10:11	Sunny	62.8	62.8	59.9	Operation of mobile crane	Mini piling in process in adjacent site	N.A	30	<5	B&K 2238 S/N : 2381580	B&K 4231 S/N: 3004068
			Min.	**63.0**									
			Max.	**75.0**									