Daytime Noise Monitoring Results -- Normal weekday

Station M7a, Wah Ming House

Date	Start Time	End Time	Weather	Noise level (dB(A)), 30 min			Major Construction Noise Source(s) Observed	Other Noise Source(s) Observed	Remarks	Temp. (°C)	Wind Speed (m/s)	Noise Meter Model / ID	Calibrator Model / ID
				Leq	L10	L90							
06-Nov-13	10:03	10:33	Cloudy	61	62	60	N.A	N.A	N.A	24.2	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068
11-Nov-13	09:21	09:51	Cloudy	68	70	64	N.A	renovation of stairs and platform in the Wah Chun House	N.A	24.1	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068
21-Nov-13	09:20	09:50	Fine	65	66	61	N.A	renovation of stairs and platform in the Wah Chun House	N.A	20.5	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068
27-Nov-13	09:35	10:05	Fine	66	67	63	N.A	renovation of stairs and platform in the Wah Chun House	N.A	20.1	<5	B&K 2238 S/N : 2684503	B&K 4231 S/N: 3004068
			Min.	**61**									
			Max.	**68**									