



**Term Contract for Provision of Sampling and Analyzing of
Wastewater and Sludge Samples for Various Sewage Treatment
Facilities and Marine Water Samples in Urban Area, Lantau and
Outlying Islands to the Drainage Services Department**

Whole Effluent Toxicity Test (WETT) at SCISTW

Report for the Month of October 2021

Contract No.

: DE/2020/02

Applicant

: DRAINAGE SERVICES DEPT. - DIVISION 2

Address

: STONECUTTERS ISLAND SEWAGE
TREATMENT WORKS, NGONG SHUEN CHAU,
KOWLOON, HONG KONG

Application No.

: LA031301(8)

Report No.

: AA0055244(9)

Report Issued Date

: 17 Nov 2021

For and on behalf of
CMA Industrial Development Foundation Limited

Authorized Signature :


Lau Yan Kin
Senior Manager

The conformity statement stated in Conclusion above is based on the decision rule agreed with applicant and listed in www.cmatesting.org/qac/statement-of-conformity.pdf.
This document is issued subject to the latest CMA Testing General Terms and Conditions of Testing and Inspection Services, available on request or accessible at website www.cmatesting.org.
This document shall not be reproduced except in full or with written approval by CMA Testing. The observations and test results in this report are relevant only to the sample tested.

CMA Industrial Development Foundation Limited

Room 1302, Yan Hing Centre, 9-13 Wong Chuk Yeung St., Fo Tan, Shatin, N.T., Hong Kong.

Tel: (852) 2698 8198 Fax: (852) 2695 4177 E-mail: info@cmatesting.org Web Site: <http://www.cmatesting.org>



Contents	2
1 Introduction	4
1.1 Background	4
1.2 Testing laboratory and investigator	4
1.3 Sample	4
1.4 Test species	4
1.5 Test protocols	4
2 Report on Amphipod Acute Toxicity Test	5
2.1 Samples storage and pretreatment	6
2.2 Test organism	6
2.3 Summary of test conditions	6
2.4 Test results	7
2.5 Summary of water quality parameters monitoring during test	8
2.6 LC ₅₀ for the amphipod <i>Melita longidactyla</i> and test acceptability	8
3 Report on Fish Acute Toxicity Test	9
3.1 Samples storage and pretreatment	10
3.2 Test organism	10
3.3 Summary of test conditions	10
3.4 Test results	11
3.5 Summary of water quality parameters monitoring during test	12
3.6 LC ₅₀ for the fish <i>Lutjanus malabaricus</i> and test acceptability	12
4 Report on Barnacle Larvae Acute Toxicity Test	13
4.1 Samples storage and pretreatment	14
4.2 Test organism	14
4.3 Summary of test conditions	14
4.4 Test results	15
4.5 Summary of water quality parameters monitoring during test	16
4.6 LC ₅₀ for the barnacle larvae <i>Balanus amphitrite</i> and test acceptability	16
5 Report on Diatom Growth Inhibition Test (Chronic toxicity test)	17
5.1 Samples storage and pretreatment	18
5.2 Test organism	18
5.3 Summary of test conditions	18
5.4 Test results	19
5.5 Summary of water quality parameters monitoring during test	20
5.6 IC ₅₀ for the diatom <i>Skeletonema costatum</i> and test acceptability	20
6 Report on Shrimp Acute Toxicity Test	21
6.1 Samples storage and pretreatment	22
6.2 Test organism	22
6.3 Summary of test conditions	22
6.4 Test results	23
6.5 Summary of water quality parameters monitoring during test	24



TESTING

6.6 LC ₅₀ for the shrimp <i>Metapenaeus ensis</i> and test acceptability	24
7 Conclusion	25-26
Appendix A Monitoring Data for Amphipod Acute Toxicity Test	27-29
Appendix B Monitoring Data for Fish Acute Toxicity Test	30-32
Appendix C Monitoring Data for Barnacle Larvae Acute Toxicity Test	33-35
Appendix D Monitoring Data for Diatom Growth Inhibition Test	36-38
Appendix E Monitoring Data for Shrimp Acute Toxicity Test	39-41



1. Introduction

1.1. Background

The whole effluent toxicity tests (WETT) were carried out under the requirements of Drainage Service Department (DSD).

1.2. Testing laboratory and investigator

Principle investigator: Prof. Wen-Xiong WANG

Phone number: (852) 3442-4693

Address: School of Energy and Environment, City University of Hong Kong, Hong Kong

1.3. Sample

A 24-hour flow-weighted composite effluent sample was collected from Stonecutters Island Sewage Treatment Works (SCISTW) on October 28, 2021. Effluent sample was shipped immediately to the testing laboratory on the same day of collection. Toxicity testings started immediately after the arrival of samples.

1.4. Test species

The following test species were included in the WETT:

- Amphipod (*Melita longidactyla*)
- Fish (*Lutjanus malabaricus*)
- Barnacle larvae (*Balanus amphitrite*)
- Diatom (*Skeletonema costatum*)
- Shrimp (*Metapenaeus ensis*)

1.5. Test protocols

The WETT testing methods and procedures follow those documented in “Consultancy Study on Fisheries and Marine Ecological Criteria for Impact Assessment-Final Report” commissioned by Agriculture, Fisheries and Conservation Department (AFCD), as indicated in tender addendum No. 1 by Drainage Services Department (DSD).



2. Report on Amphipod Acute Toxicity Test

Test report

2.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove the large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

2.2. Test organism

Species	Amphipod (<i>Melita longidactyla</i>).
Source:	Collected from local coastal waters from Sai Kung
Size/age:	0.5-0.7 cm
Acclimatization:	Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 30‰) at least 48 hours in the laboratory prior to test. Fed with green algae <i>Ulva lactuca</i> .

2.3. Summary of test conditions

Type of test:	Static
Duration:	48 h, 28/10/2021-30/10/2021
Dilution seawater source:	Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong
Dilution seawater pretreatment:	Filtered through 0.22 µm membrane
Testing temperature:	22±1 °C
Lighting:	Continuous
Salinity:	30‰
Testing chamber:	Pre-cleaned 150 mL glass flask
Feeding:	None
Number of organisms per replicate:	10
Replicate number:	4
Volume of test medium:	100 mL
Aeration:	Moderate, around 100 bubbles/min
Reference toxicant:	CdCl ₂
Positive control:	48-h acute toxicity test
Salinity control:	Prepared with ocean salt adding into de-ionized water, salinity: 30‰



2.4. Test results

Table 1. Survival of amphipods after 48 hours.

Treatment	Effluent concentration (%)	Number of living amphipods after 48 hour (individuals)				Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4		
Negative control	0	10	9	9	10	9.50	0.58
Salinity control	0	9	10	8	10	9.25	0.96
Concentration 1	6.5	8	10	8	10	9.00	1.15
Concentration 2	12.5	10	8	8	7	8.25	1.26
Concentration 3	25	8	7	8	6	7.25	0.96
Concentration 4	50	3	4	4	3	3.50	0.58
Concentration 5	100	0	0	0	0	0.00	0.00

Table 2. Survival percentage of amphipods after 48 hours.

Treatment	Effluent concentration (%)	Percentage of living amphipods after 48 hour (%)				Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4		
Negative control	0	100	90	90	100	95.00	5.78
Salinity control	0	90	100	80	100	92.50	9.57
Concentration 1	6.5	80	100	80	100	90.00	11.55
Concentration 2	12.5	100	80	80	70	82.50	12.58
Concentration 3	25	80	70	80	60	72.50	9.57
Concentration 4	50	30	40	40	30	35.00	5.77
Concentration 5	100	0	0	0	0	0.00	0.00

2.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during amphipod acute toxicity test.

Water quality parameters	Effluent concentration (%)						
	Negative control	Salinity control	6.5	12.5	25	50	100
Salinity (‰)	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Dissolved oxygen (mg L ⁻¹)	6.8-7.2	6.8-7.1	6.9-7.1	6.9-7.1	6.8-7.1	6.9-7.0	6.8-7.0
Temperature (°C)	22.0	22.0	22.0	22.0	22.0	22.0	22.0
pH	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.0	7.8-8.1	7.8-7.9
Total ammonia (start/end, mg L ⁻¹)	0.02/1.63	0.04/1.65	2.56/4.24	2.96/5.78	3.05/7.73	18.1/16.2	27.8/17.9
Total sulfide (start/end, mg L ⁻¹)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	0.2/<0.1
Total residual chlorine (start/end, mg L ⁻¹)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
Total suspended solid (start/end, mg L ⁻¹)	<2/<2	3/3	17/17	29/28	34/26	42/29	54/37

2.6. LC₅₀ for the amphipod *Melita longidactyla* and test acceptability

Table 4. LC₅₀ for the amphipods and test acceptability.

Parameter	Value	Control limit
Calculated LC ₅₀	40.3 %	NA
Negative control survival	95%	>90%
Reference toxicant 48-h acute test	0.91 mg L ⁻¹	1.25±0.15 mg L ⁻¹
95% of confidence range of reference toxicant test	0.67-1.16 mg L ⁻¹	NA
Daily temperature variation	<0.5 °C	Average daily temperature variation: ±1 °C
Dissolved oxygen concentration	>6.7 mg L ⁻¹	>4 mg L ⁻¹

NA: Not applicable



3. Report on Fish Acute Toxicity Test

Test report

3.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

3.2. Test organism

Species	Fish (<i>Lutjanus malabaricus</i>)
Source:	Purchased from contracted fish farm
Size/age:	2-3 cm
Acclimatization:	Acclimatized in fully aerated seawater (temperature: 22±1°C, salinity: 30‰) at least 48 hours in laboratory prior to test. Fed with fresh shrimp purchased from local market.

3.3. Summary of test conditions

Type of test:	Static
Duration:	48 h, 28/10/2021-30/10/2021
Dilution seawater source:	Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong
Dilution seawater pretreatment:	Filtered through 5 µm filtration bag
Testing temperature:	22±1 °C
Lighting:	Continuous
Salinity:	30‰
Testing chamber:	Pre-cleaned 20 L tank
Feeding:	None
Number of organisms per replicate:	20
Replicate number:	4
Volume of test medium:	20 L
Aeration:	Moderate, with air stone
Reference toxicant:	CdCl ₂
Positive control:	48 h acute toxicity test
Salinity control:	Prepared with ocean salt adding into de-ionized water, salinity: 30‰



3.4. Test results

Table 1. Survival of fish after 48 hours.

Treatment	Effluent concentration (%)	Number of living fish after 48 hour (individuals)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	20	19	18	20	19.25	0.96	
Salinity control	0	20	20	20	18	19.50	1.00	
Concentration 1	6.5	16	17	16	15	16.00	0.82	
Concentration 2	12.5	15	14	17	13	14.75	1.71	
Concentration 3	25	15	10	19	11	13.75	4.11	
Concentration 4	50	4	4	4	0	3.00	2.00	
Concentration 5	100	0	1	1	4	1.50	1.73	

Table 2. Survival percentage of fish after 48 hours.

Treatment	Effluent concentration (%)	Percentage of living fish after 48 hour (%)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	100	95	90	100	96.25	4.79	
Salinity control	0	100	100	100	90	97.50	5.00	
Concentration 1	6.5	80	85	80	75	80.00	4.08	
Concentration 2	12.5	75	70	85	65	73.75	8.54	
Concentration 3	25	75	50	95	55	68.75	20.56	
Concentration 4	50	20	20	20	0	15.00	10.00	
Concentration 5	100	0	5	5	20	7.50	8.66	

3.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during fish acute toxicity test.

Water quality parameters	Effluent concentration (%)						
	Negative control	Salinity control	6.5	12.5	25	50	100
Salinity (‰)	30	30	30	30	30	30	30
Dissolved oxygen (mg L ⁻¹)	6.8-7.0	6.9-7.1	6.9-7.1	6.8-7.1	6.8-7.0	6.8-7.1	6.7-7.0
Temperature (°C)	22	22	22	22	22	22	22
pH	7.9-8.0	7.8-8.0	7.9-8.0	7.7-8.1	7.8-8.1	7.8-8.0	7.9-8.0
Total ammonia (start/end, mg L ⁻¹)	0.2/<0.01	0.2/<0.01	3.2/1.7	6.1/5.8	8.0/7.5	12.5/11.6	17.5/15.0
Total sulfide (start/end, mg L ⁻¹)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	0.2/0.1
Total residual chlorine (start/end, mg L ⁻¹)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
Total suspended solid (mg L ⁻¹)	<2 /<2	<2 /<2	7/7	7/7	21/7	29/14	57/37

3.6. LC₅₀ for the fish *Lutjanus malabaricus* and test acceptability

Table 4. LC₅₀ for the fish and test acceptability.

Parameter	Value	Control limit
Calculated LC ₅₀	34.4 %	NA
Negative survival	96.25 %	>90%
Reference toxicant 48-h acute test	11.5 mg L ⁻¹	14.6±1.78 mg L ⁻¹
95% of confidence range of reference toxicant test	9.5-13.7 mg L ⁻¹	NA
Daily temperature variation	<0.5 °C	Average daily temperature variation: ± 1 °C
Dissolved oxygen concentration	>6.6 mg L ⁻¹	>4 mg L ⁻¹

NA: Not applicable



4. Report on Barnacle Larvae Acute Toxicity Test



Test report

4.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 5 µm membrane filter to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30%) and then aerated moderately to dissolved oxygen (DO) saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

4.2. Test organism

Species	Barnacle larvae (<i>Balanus amphitrite</i>).
Source:	Introduced from adult barnacles collected from Sai Kung
Size/age:	Stage II
Acclimatization:	Acclimatized in fully aerated seawater held in 500 mL glass beaker (temperature: 22±1°C, salinity: 30‰) for at least 24 hours in laboratory prior to test. Fed with diatom <i>Chaetoceros gracilis</i> .

4.3. Summary of test conditions

Type of test:	Static
Duration:	48 h, 28/10/2021-30/10/2021
Dilution seawater source:	Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong
Dilution seawater pretreatment:	Filtered through 0.22 µm membrane
Testing temperature:	22±1 °C
Lighting:	Continuous
Salinity:	30‰
Testing chamber:	Pre-cleaned 50 mL glass beaker
Feeding:	None
Number of organisms per replicate:	20
Replicate number:	4
Volume of test medium:	20 mL
Aeration:	Moderate, around 100 bubbles/min
Reference toxicant:	CdCl ₂
Positive control:	48 h acute toxicity test
Salinity control:	Prepared with ocean salt adding into de-ionized water, salinity: 30‰



4.4. Test results

Table 1. Survival of barnacle larvae after 48 hours.

Treatment	Effluent concentration (%)	Number of living barnacle larvae after 48 hour (individuals)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	20	20	20	20	20	20.00	0.00
Salinity control	0	20	20	20	20	20	20.00	0.00
Concentration 1	6.5	20	19	18	19	19	19.00	0.82
Concentration 2	12.5	20	19	18	18	18	18.75	0.96
Concentration 3	25	16	14	16	16	16	15.50	1.00
Concentration 4	50	11	11	13	12	12	11.75	0.96
Concentration 5	100	4	2	1	1	1	2.00	1.41

Table 2. Survival percentage of barnacle larvae after 48 hours.

Treatment	Effluent concentration (%)	Percentage of living barnacle larvae after 48 hour (%)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	100	100	100	100	100	100.00	0.00
Salinity control	0	100	100	100	100	100	100.00	0.00
Concentration 1	6.5	100	95	90	95	95	95.00	4.08
Concentration 2	12.5	100	95	90	90	90	93.75	4.79
Concentration 3	25	80	70	80	80	80	77.50	5.00
Concentration 4	50	55	55	65	60	60	58.75	4.79
Concentration 5	100	20	10	5	5	5	10.00	7.07

4.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during barnacle larvae acute toxicity test

Water quality parameters	Effluent concentration (%)						
	Negative control	Salinity control	6.5	12.5	25	50	100
Salinity (‰)	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Dissolved oxygen (mg L ⁻¹)	6.8-6.9	6.8-7.0	6.8-7.0	6.8-6.9	6.8-7.0	6.8-7.1	6.8-6.9
Temperature (°C)	22.0	22.0	22.0	22.0	22.0	22.0	22.0
pH	7.8-8.0	7.8-8.0	7.9-8.0	7.9-8.0	7.8-7.9	7.7-7.9	7.7-7.8
Total ammonia (start/end, mg L ⁻¹)	<0.01/<0.01	<0.01/0.03	1.40/1.68	2.63/2.14	4.27/5.42	15.9/8.51	26.8/19.7
Total sulfide (start/end, mg L ⁻¹)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Total residual chlorine (start/end, mg L ⁻¹)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
Total suspended solid (mg L ⁻¹)	<2/<2	<2/<2	4/3	6/3	20/17	28/17	30/17

4.6. LC₅₀ for the barnacle larvae *Balanus amphitrite* and test acceptability

Table 4. LC₅₀ for the barnacle larvae and test acceptability

Parameter	Value	Control limit
Calculated LC ₅₀	46.2%	NA
Negative survival	100 %	>90%
Reference toxicant 48-h acute test	1.02 mg L ⁻¹	1.04±0.11 mg L ⁻¹
95% of confidence range of reference toxicant test:	0.75-1.34 mg L ⁻¹	NA
Daily temperature variation	<0.5°C	Average daily temperature variation: ± 1 °C
Dissolved oxygen concentration	>6.7 mg L ⁻¹	>4 mg L ⁻¹

NA: Not applicable



5. Report on Diatom Growth Inhibition Test (Chronic toxicity test)

Test report

5.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 5 µm membrane filter to remove large debris. Effluent was added with ocean salt in order to raise the salinity to the required level (30‰) and then aerated moderately to dissolved oxygen (DO) saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

5.2. Test organism

Species	Diatom (<i>Skeletonema costatum</i>)
Source:	Grown from laboratory culture obtained from Coastal Marine Lab, Hong Kong University of Science and Technology
Size/ age:	Log growth phase
Acclimatization:	Grown in 250 mL glass flask (temperature: 22±1°C, salinity: 30‰, 3000 lux) for at least two weeks prior to test.

5.3. Summary of test conditions

Type of test:	Static
Duration:	7 days, 28/10/2021-04/11/2021
Dilution seawater source:	Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong
Dilution seawater pretreatment:	Filtered through 0.22 µm membrane
Testing temperature:	22±1 °C
Lighting:	12 h light/12 h dark cycle, 3000±500 lux
Salinity:	30‰
Testing chamber:	Pre-cleaned 100 mL glass beaker
Initial cell density:	(5.0±0.4)×10 ⁴ cell mL ⁻¹
Replicate number:	4
Volume of test medium:	25 mL
Aeration:	None
Reference toxicant:	CdCl ₂
Positive control:	7-day IC ₅₀ toxicity test
Salinity control:	Prepared with ocean salt adding into de-ionized water, salinity: 30‰

5.4. Test results

Table 1. Cell density of diatom *Skeletonema costatum* at the beginning and end of growth inhibition test. Initial cell density: $(5.0 \pm 0.4) \times 10^4$ cell mL $^{-1}$.

Treatment	Effluent concentration (%)	Cell density after 7-day growth ($\times 10^6$ cell mL $^{-1}$)				
		Replicate 1	Replicate 2	Replicate 3	Replicate 4	Mean
Negative control	0	1.20	1.16	1.12	1.14	1.16
Salinity control	0	1.13	1.12	1.15	1.15	1.14
Concentration 1	2.5	1.21	1.11	1.22	1.25	1.20
Concentration 2	5	1.95	2.03	2.17	2.01	2.04
Concentration 3	10	1.69	1.53	1.59	1.59	1.60
Concentration 4	25	0.98	1.13	1.02	0.98	1.03
Concentration 5	50	0.75	0.84	0.87	0.73	0.80
Concentration 6	100	0.48	0.52	0.66	0.53	0.55

Table 2. Growth rate of *Skeletonema costatum* within 7 days.

Treatment	Effluent concentration (%)	7-day average growth rate (d $^{-1}$)				
		Replicate 1	Replicate 2	Replicate 3	Replicate 4	Mean
Negative control	0	0.45	0.45	0.44	0.45	0.45
Salinity control	0	0.45	0.44	0.45	0.45	0.45
Concentration 1	2.5	0.46	0.44	0.46	0.46	0.45
Concentration 2	5	0.52	0.53	0.54	0.53	0.53
Concentration 3	10	0.50	0.49	0.49	0.49	0.50
Concentration 4	25	0.43	0.45	0.43	0.43	0.43
Concentration 5	50	0.39	0.40	0.41	0.38	0.40
Concentration 6	100	0.32	0.33	0.37	0.34	0.34

5.5. Summary of water quality parameters monitoring during test

Table 3. Summary of water quality parameters during diatom growth inhibition test

Water quality parameters	Effluent concentration (%)							
	Negative control	Salinity control	2.5	5.0	10	25	50	100
Salinity (‰)	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0
Dissolved oxygen (mg L ⁻¹)	6.8-8.2	6.8-8.2	6.8-8.2	6.8-8.2	6.8-8.3	6.8-8.2	6.8-7.9	6.8-7.3
Temperature (°C)	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
pH	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.1	7.9-8.0
Total ammonia (start/end, mg L ⁻¹)	0.01/0.01	0.01/0.01	0.54/0.83	1.05/1.37	2.31/1.98	3.92/4.19	8.79/7.57	20.5/17.1
Total sulfide (start/end, mg L ⁻¹)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Total residual chlorine (start/end, mg L ⁻¹)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
Total suspended solid (mg L ⁻¹)	<2/<2	<2/<2	2/3	5/8	9/8	15/26	38/27	86/65

5.6. IC₅₀ for the diatom *Skeletonema costatum* and test acceptability

Table 4. IC₅₀, none observed effect concentration (NOEC) for the diatom and test acceptability

Parameter	Value	Control limit
Calculated IC ₅₀	87.3 %	NA
None observed effect concentration (NOEC)	10 %	-
Reference toxicant 7-day test:	0.14 mg L ⁻¹	0.13±0.02 mg L ⁻¹
95% of confidence range of reference toxicant test	0.08-0.17 mg L ⁻¹	NA
Temperature variation	<0.5 °C	Average daily temperature variation: ± 1 °C

NA: Not applicable



6. Report on Shrimp Acute Toxicity Test

Test report

6.1. Samples storage and pretreatment

Effluent sample was thoroughly mixed and passed through 2-mm mesh to remove the large debris. Effluent was added with ocean salt in order to raise the salinity to 25‰ and then aerated moderately such that the dissolved oxygen (DO) reached saturation prior to use. Salinity control was set up to monitor if there was adverse effect on the test organisms.

6.2. Test organism

Species	Shrimp (<i>Metapenaeus ensis</i>)
Source:	Purchased from contracted fish dealer
Size/age:	5-7 cm
Acclimatization:	Acclimatized in fully aerated seawater (temperature: $22\pm1^{\circ}\text{C}$, salinity: 25‰) at least 48 hours in the laboratory prior to test. Fed with commercial shrimp feeds.

6.3. Summary of test conditions

Type of test:	Static
Duration:	48 h, 28/10/2021-30/10/2021
Dilution seawater source:	Seawater collected from a pristine site in Clear Water Bay, Sai Kung, Hong Kong
Dilution seawater pretreatment:	Filtered through 0.22 μm membrane
Testing temperature:	$22\pm1^{\circ}\text{C}$
Lighting:	Continuous
Salinity:	25‰
Testing chamber:	Pre-cleaned 20 L tank
Feeding:	None
Number of organisms per replicate:	10
Replicate number:	4
Volume of test medium:	10 L
Aeration:	Moderate, with air stone
Reference toxicant:	CdCl_2
Positive control:	48 h acute toxicity test
Salinity control:	Prepared with ocean salt adding into de-ionized water, salinity: 25‰



6.4. Test results

Table 1. Survival of shrimps after 48 hours.

Treatment	Effluent concentration (%)	Number of living shrimps after 48 hour (individuals)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	10	10	10	9	9.75	0.50	
Salinity control	0	9	10	9	7	8.75	1.26	
Concentration 1	6.5	9	9	8	10	9.00	0.82	
Concentration 2	12.5	10	6	7	9	8.00	1.83	
Concentration 3	25	10	8	7	6	7.75	1.71	
Concentration 4	50	7	5	9	8	7.25	1.71	
Concentration 5	100	3	5	5	6	4.75	1.26	

Table 2. Survival percentage of shrimps after 48 hours.

Treatment	Effluent concentration (%)	Percentage of living shrimps after 48 hour (%)					Mean	SD
		Replicate 1	Replicate 2	Replicate 3	Replicate 4			
Negative control	0	100	100	100	90	97.50	5.00	
Salinity control	0	90	100	90	70	87.50	12.58	
Concentration 1	6.5	90	90	80	100	90.00	8.16	
Concentration 2	12.5	100	60	70	90	80.00	18.26	
Concentration 3	25	100	80	70	60	77.50	17.08	
Concentration 4	50	70	50	90	80	72.50	17.08	
Concentration 5	100	30	50	50	60	47.50	12.58	

6.5. Summary of water quality parameters monitoring during test.

Table 3. Summary of water quality parameters during shrimp acute toxicity test.

Water quality parameters	Effluent concentration (%)						
	Negative control	Salinity control	6.5	12.5	25	50	100
Salinity (‰)	25.0	25.0	25.0	25.0	25.0	25.0	25.0
Dissolved oxygen (mg L ⁻¹)	6.8-6.9	6.9-7.0	6.9-7.0	6.9-7.0	6.9-7.1	6.8-7.0	6.8-7.0
Temperature (°C)	22.0	22.0	22.0	22.0	22.0	22.0	22.0
pH	7.9-8.0	7.9-8.0	7.9-8.0	7.9-7.9	7.9-8.0	7.7-7.9	7.7-8.0
Total ammonia (start/end, mg L ⁻¹)	0.65/0.01	0.13/0.01	1.57/1.29	3.34/3.02	5.71/5.12	6.48/11.4	17.6/22.7
Total sulfide (start/end, mg L ⁻¹)	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
Total residual chlorine (start/end, mg L ⁻¹)	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
Total suspended solid (start/end, mg L ⁻¹)	<2/<2	<2/<2	6/5	9/9	13/9	19/18	37/28

6.6. LC₅₀ for the shrimp *Metapenaeus ensis* and test acceptability

Table 4. LC₅₀ for the *Metapenaeus ensis* and test acceptability.

Parameter	Value	Control limit
Calculated LC ₅₀	94.0 %	NA
Negative control survival	97.5 %	>90%
Reference toxicant 48-h acute test	6.52 mg L ⁻¹	5.19±0.51 mg L ⁻¹
95% of confidence range of reference toxicant test	4.47-9.76 mg L ⁻¹	NA
Daily temperature variation	<0.5 °C	Average daily temperature variation: ±1 °C
Dissolved oxygen concentration	>6.7 mg L ⁻¹	>4 mg L ⁻¹

NA: Not applicable

7. Conclusion

Table 1. Comparison of measured toxicity values with the target toxicity levels.

Test species	Measured LC ₅₀ /IC ₅₀ /NOEC	Target toxicity level
Amphipod <i>Melita longidactyla</i>	40.3 %	≥7.1%
Fish <i>Lutjanus malabaricus</i>	34.4 %	≥7.1%
Barnacle larvae <i>Balanus amphitrite</i>	46.2 %	≥7.1%
Diatom <i>Skeletonema costatum</i>	87.3 %	-
Diatom <i>Skeletonema costatum</i>	10 % (NOEC)	≥0.51%
Shrimp <i>Metapenaeus ensis</i>	94.0 %	≥7.1%

Conclusion: all the measured values met the target toxicity levels as indicated in the EM&A Manual.



TESTING

Appendix A

Monitoring Data for Amphipod Acute Toxicity Test



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in amphipod acute toxicity test.

Concentration treatment (%)	Dissolved oxygen (mg L ⁻¹)					pH				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	6.9	7.2	7.2	6.9	6.8	7.9	7.9	8.1	8.1	8.0
Salinity control	6.8	6.9	7.1	7.1	7.0	7.9	8.0	8.1	8.1	8.1
6.5	6.9	7.0	7.0	7.0	7.1	8.0	7.9	8.1	8.1	8.1
12.5	6.9	6.9	7.0	7.1	7.0	8.0	8.0	8.0	7.9	8.1
25	6.8	7.1	7.1	7.1	7.0	8.0	7.9	7.9	7.9	8.0
50	6.9	7.0	6.9	6.9	6.9	7.8	7.9	8.0	8.1	8.0
100	7.0	6.9	6.9	6.8	6.9	7.8	7.8	7.9	7.9	7.8

Table 2. Salinity and temperature in each concentration treatment in amphipod acute toxicity test.

Concentration treatment (%)	Salinity (‰)					Temperature (°C)				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
Salinity control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
6.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
12.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
25	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
50	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
100	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the amphipod acute toxicity test.

Concentration treatment (%)	Ammonia-N (mg L ⁻¹)		Sulphide (mg L ⁻¹)		Total suspended solids (mg L ⁻¹)		Total residual chlorine (mg L ⁻¹)	
	Initial	End	Initial	End	Initial	End	Initial	End
Negative control	0.02	1.63	<0.1	<0.1	<2	<2	<0.02	<0.02
Salinity control	0.04	1.65	<0.1	<0.1	3	3	<0.02	<0.02
6.5	2.56	4.24	<0.1	<0.1	17	17	<0.02	<0.02
12.5	2.96	5.78	<0.1	<0.1	29	28	<0.02	<0.02
25	3.05	7.73	<0.1	<0.1	34	26	<0.02	<0.02
50	18.1	16.2	<0.1	<0.1	42	29	<0.02	<0.02
100	27.8	17.9	0.2	<0.1	54	37	<0.02	<0.02



Appendix B

Monitoring Data for Fish Acute Toxicity Test



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in fish acute toxicity test.

Concentration treatment (%)	Dissolved oxygen (mg L ⁻¹)					pH				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	6.8	6.9	7.0	6.9	7.0	7.9	7.9	7.9	8.0	7.9
Salinity control	6.9	6.9	7.0	7.0	7.1	8.0	7.9	7.9	7.9	7.8
6.5	6.9	7.1	7.1	7.0	7.0	7.9	7.9	7.9	7.8	8.0
12.5	6.8	6.9	6.9	7.0	7.1	8.1	8.0	7.9	7.9	7.7
25	7.0	6.9	7.0	6.8	6.9	8.0	8.1	7.9	7.8	7.9
50	6.9	6.9	7.1	6.8	6.8	7.9	8.0	8.0	7.9	7.8
100	7.0	6.8	6.7	6.8	6.8	7.9	8.0	7.9	7.9	7.9

Table 2. Salinity and temperature in each concentration treatment in fish acute toxicity test.

Concentration treatment (%)	Salinity (‰)					Temperature (°C)				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
Salinity control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
6.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
12.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
25	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
50	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
100	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0



Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the fish acute toxicity test.

Concentration treatment (%)	Ammonia-N (mg L ⁻¹)		Sulphide (mg L ⁻¹)		Total suspended solids (mg L ⁻¹)		Total residual chlorine (mg L ⁻¹)	
	Initial	End	Initial	End	Initial	End	Initial	End
Negative control	0.2	<0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
Salinity control	0.2	<0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
6.5	3.2	1.7	<0.1	<0.1	7	7	<0.02	<0.02
12.5	6.1	5.8	<0.1	<0.1	7	7	<0.02	<0.02
25	8.0	7.5	<0.1	<0.1	21	7	<0.02	<0.02
50	12.5	11.6	<0.1	<0.1	29	14	<0.02	<0.02
100	17.5	15.0	0.2	0.1	57	37	<0.02	<0.02

Appendix C

Monitoring Data for Barnacle Larvae Acute Toxicity Test



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in barnacle larvae acute toxicity test.

Concentration treatment (%)	Dissolved oxygen (mg L ⁻¹)					pH				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	6.8	6.9	6.9	6.9	6.8	7.9	8.0	8.0	7.9	7.8
Salinity control	6.9	6.9	7.0	7.0	6.8	7.9	8.0	8.0	7.8	7.8
6.5	6.9	7.0	6.8	6.9	6.8	8.0	7.9	7.9	7.9	8.0
12.5	6.9	6.9	6.9	6.8	6.8	7.9	7.9	7.9	7.9	8.0
25	6.9	6.9	6.8	6.9	7.0	7.9	7.8	7.8	7.8	7.8
50	6.8	6.9	6.9	6.9	7.1	7.9	7.9	7.9	7.8	7.7
100	6.8	6.8	6.8	6.9	6.8	7.8	7.8	7.8	7.8	7.7

Table 2. Salinity and temperature in each concentration treatment in barnacle larvae acute toxicity test.

Concentration treatment (%)	Salinity (‰)					Temperature (°C)				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
Salinity control	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
6.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
12.5	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
25	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
50	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0
100	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0



Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the barnacle larvae acute toxicity test.

Concentration treatment (%)	Ammonia-N (mg L ⁻¹)		Sulphide (mg L ⁻¹)		Total suspended solids (mg L ⁻¹)		Total residual chlorine (mg L ⁻¹)	
	Initial	End	Initial	End	Initial	End	Initial	End
Negative control	<0.01	<0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
Salinity control	<0.01	0.03	<0.1	<0.1	<2	<2	<0.02	<0.02
6.5	1.40	1.68	<0.1	<0.1	4	3	<0.02	<0.02
12.5	2.63	2.14	<0.1	<0.1	6	3	<0.02	<0.02
25	4.27	5.42	<0.1	<0.1	20	17	<0.02	<0.02
50	15.9	8.51	<0.1	<0.1	28	17	<0.02	<0.02
100	26.8	19.7	<0.1	<0.1	30	17	<0.02	<0.02



Appendix D

Monitoring Data for Diatom Growth Inhibition Test (Chronic toxicity test)



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in diatom growth inhibition test.

Concentration treatment (%)	Dissolved oxygen (mg L ⁻¹)								pH							
	0 h	24 h	48 h	72 h	96 h	120 h	144 h	168 h	0 h	24 h	48 h	72 h	96 h	120 h	144 h	168 h
Negative control	6.8	6.9	7.1	7.2	7.5	7.7	8.0	8.2	8.0	7.9	8.0	8.0	7.9	8.1	8.1	8.1
Salinity control	6.9	6.8	7.0	7.2	7.4	7.8	7.9	8.2	7.9	7.9	8.1	8.0	8.0	8.1	8.0	8.1
2.5	6.9	6.9	7.2	7.2	7.6	7.8	8.1	8.2	8.0	7.9	7.9	8.0	8.1	8.1	8.1	8.0
5	6.8	6.8	7.1	7.1	7.6	7.9	8.0	8.2	8.0	8.0	8.1	8.0	7.9	7.9	8.0	8.1
10	6.8	6.9	7.1	7.3	7.4	7.6	7.9	8.3	7.9	7.9	8.0	8.1	8.0	8.0	8.0	8.1
25	6.9	6.8	7.0	7.1	7.2	7.6	7.8	8.2	7.9	8.0	8.0	8.0	8.1	8.0	7.9	8.0
50	6.8	6.9	7.0	7.2	7.4	7.4	7.6	7.8	7.9	7.9	7.9	8.0	8.0	8.0	8.1	8.0
100	6.9	6.8	6.9	6.9	6.9	7.1	7.2	7.3	7.9	7.8	7.9	7.9	7.9	7.9	8.0	8.0

Table 2. Salinity and temperature in each concentration treatment in diatom growth inhibition test.

Concentration treatment (%)	Salinity (‰)								Temperature (°C)							
	0 h	24h	48h	72h	96h	120h	144h	168h	0h	24h	48h	72h	96h	120h	144h	168h
Negative control	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
Salinity control	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
2.5	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
5	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
10	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
25	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
50	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0
100	30.0	30.0	30.0	30.0	30.0	30.0	30.0	30.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0

Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the diatom growth inhibition toxicity test.

Concentration treatment (%)	Ammonia-N (mg L ⁻¹)		Sulphide (mg L ⁻¹)		Total suspended solids (mg L ⁻¹)		Total residual chlorine (mg L ⁻¹)	
	Initial	End	Initial	End	Initial	End	Initial	End
Negative control	0.01	0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
Salinity control	0.01	0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
2.5	0.54	0.83	<0.1	<0.1	2	3	<0.02	<0.02
5	1.05	1.37	<0.1	<0.1	5	8	<0.02	<0.02
10	2.31	1.98	<0.1	<0.1	9	8	<0.02	<0.02
25	3.92	4.19	<0.1	<0.1	15	26	<0.02	<0.02
50	8.79	7.57	<0.1	<0.1	38	27	<0.02	<0.02
100	20.5	17.1	<0.1	<0.1	86	65	<0.02	<0.02



Appendix E

Monitoring Data for Shrimp Acute Toxicity Test



Table 1. Dissolved oxygen concentration and pH in each concentration treatment in shrimp acute toxicity test.

Concentration treatment (%)	Dissolved oxygen (mg L ⁻¹)					pH				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	6.8	6.9	6.9	6.9	6.8	7.9	7.9	8.0	8.0	8.0
Salinity control	6.9	6.9	6.9	7.0	7.0	8.0	7.9	8.0	7.9	8.0
6.5	6.9	6.9	6.9	7.0	7.0	7.9	7.9	8.0	8.0	7.9
12.5	6.9	6.9	6.9	7.0	6.9	7.9	7.9	7.9	7.9	7.9
25	6.9	7.1	7.0	7.0	7.0	8.0	8.0	7.9	8.0	7.9
50	6.9	7.0	7.0	6.9	6.8	7.9	7.9	7.9	7.7	7.7
100	7.0	7.0	6.9	6.8	6.8	7.9	8.0	7.9	7.8	7.7

Table 2. Salinity and temperature in each concentration treatment in shrimp acute toxicity test.

Concentration treatment (%)	Salinity (‰)					Temperature (°C)				
	0 h	12 h	24 h	36 h	48 h	0 h	12 h	24 h	36 h	48 h
Negative control	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
Salinity control	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
6.5	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
12.5	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
25	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
50	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0
100	25.0	25.0	25.0	25.0	25.0	22.0	22.0	22.0	22.0	22.0



Table 3. Ammonia-N, sulphide, total suspended solids, total residual chlorine concentration at the beginning and ending of the shrimp acute toxicity test.

Concentration treatment (%)	Ammonia-N (mg L ⁻¹)		Sulphide (mg L ⁻¹)		Total suspended solids (mg L ⁻¹)		Total residual chlorine (mg L ⁻¹)	
	Initial	End	Initial	End	Initial	End	Initial	End
Negative control	0.65	0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
Salinity control	0.13	0.01	<0.1	<0.1	<2	<2	<0.02	<0.02
6.5	1.57	1.29	<0.1	<0.1	6	5	<0.02	<0.02
12.5	3.34	3.02	<0.1	<0.1	9	9	<0.02	<0.02
25	5.71	5.12	<0.1	<0.1	13	9	<0.02	<0.02
50	6.48	11.4	<0.1	<0.1	19	18	<0.02	<0.02
100	17.6	22.7	<0.1	<0.1	37	28	<0.02	<0.02